

851 Chemung Street
Horseheads, New York 14845

September 30, 2019

Tom Skebey, Code Enforcement
Town of Horseheads
150 Wygant Road
Horseheads, NY 14845

RE: Hickory Grove Road Solar Facility NY Horseheads I, LLC & NY Horseheads II, LLC, Horseheads (T), Chemung (Co) NY

Mr. Skebey,

I have completed a review of the following information for the project listed above regarding the Stormwater Pollution Prevention Plan (SWPPP) for the project.

- Stormwater Pollution Prevention Plan (SWPPP) for Hickory Grove Road Solar Facility, Stamped by a Professional Engineer, Prepared by JHA Companies, Dated September 20, 2019 and Received September 24, 2019
- Stormwater Pollution Prevention Plan Drawings, Stamped by a Professional Engineer, Prepared by JHA Companies, Revised September 23, 2019, Received September 24, 2019


Based upon my review of the above submitted information, I believe that the erosion and sediment control plan is in compliance with the Town of Horsehead's Stormwater Management and Erosion and Sediment Control Law.

1. Silt and/or sediment shall not be allowed to leave the project site, including tracking onto public streets. Erosion and sediment controls, outlined in the accepted Erosion & Sediment Control Plan, shall be implemented and maintained to ensure this purpose. If silt, sediment, and/or dust are found to be leaving the site, the Owner (or their contractor) shall take immediate actions to correct the situation.

2. Owner/Operator shall not disturb greater than 5 acres at one time without prior authorization.
3. It is incumbent upon the Owner/Operator to obtain all necessary regulatory approvals and permits, including the drive access permit. It is requested that copies of all necessary regulatory approvals/permits be provided to the Town of Horseheads Code Enforcement Officer for their records.
4. Prior to the start of construction, it is requested that the owner/operator arrange a meeting the Town of Horseheads Code Enforcement Officer, the Chemung County Stormwater Coalition, contractor and the owner/operators design professional, to discuss requirements associated with the SWPPP and SPDES permit.
5. One set of the Final Erosion and Sediment Control Plan must be on-site at all times during construction and site stabilization.

If you have any questions regarding these comments, please do not hesitate to contact us.

Sincerely,



Jessica Verrigni, CPESC, CPSWQ

Cc- J. Burdett, JHA Companies
J. Carl, Chemung County Stormwater
A. Avery, Chemung County Department of Public Works